



Linda S. Adams
Secretary for
Environmental Protection

California Regional Water Quality Control Board San Diego Region

Over 50 Years Serving San Diego, Orange, and Riverside Counties
Recipient of the 2004 Environmental Award for Outstanding Achievement from USEPA



Arnold Schwarzenegger
Governor

9174 Sky Park Court, Suite 100, San Diego, California 92123-4353
(858) 467-2952 • Fax (858) 571-6972
<http://www.waterboards.ca.gov/sandiego>

September 20, 2010

In reply refer to:
Adai:244506

Mr. Steve Meyer, Deputy Director
Metropolitan Wastewater Division
City of San Diego
2392 Kincaid Road
San Diego, CA 92101-2309

Dear Mr. Meyer

**SUBJECT: REVIEW OF MONITORING REPORTS FOR NORTH CITY WATER
RECLAMATION PLANT**

The California Regional Water Quality Control Board, San Diego Region (San Diego Water Board) has reviewed the April 2010 through July 2010 monthly, and April-June 2010 quarterly monitoring reports submitted by the City of San Diego in accordance with the Monitoring and Reporting Program of Order No. 97-03.

The following violations of the Order No. 97-03 were identified in the submitted monitoring reports:

1. The 12-month average effluent limitation for manganese of the discharge specification, established at 0.05 milligrams per liter (mg/L), was exceeded in April, May, June, and July 2010 with reported values of 0.064 mg/L.

Please be aware these violations subject you to possible further enforcement action by the San Diego Water Board, including administrative enforcement orders requiring the you to cease and desist from violations, or to clean up waste and abate existing or threatened conditions of pollution or nuisance; administrative assessment of civil liability in amounts of up to \$5,000 per day per violation;¹ and referral to the State Attorney General for injunctive relief.

The next monitoring report to be submitted is the August 2010 monthly monitoring report due by September 30, 2010.

¹ Under authority of California Water Code section 13350.

Mr. Meyer

- 2 -

September 20, 2010

In the subject line of any response, please include the requested "In reply refer to:" information located in the heading of this letter. For questions pertaining to the subject matter, please contact Amanda Dai at (858) 627-3977 or via email at adai@waterboards.ca.gov.

Sincerely,

Robert Morris

Robert Morris, P.E.
Senior Water Resource Control Engineer
Cleanup and Land Discharge Branch

Regulatory Measure ID: 375901
Violation ID: 880995, 880996, 880997, 880998